

Low-Emitting Materials

Certificate of Compliance

Awarded to: **H.B. FULLER CONSTRUCTION PRODUCTS, INC.**
OF AURORA, IL 1105 SOUTH FRONTENAC ST., ZIP CODE: 60504

Category: Construction Materials - Adhesives & Sealants
Cert. Scheme: VOC Emissions

Accredited
Compliance
Designation: California Dept. of Public Health Standard Method v1.2 classroom & private office

*Conforms
With LEED v4 ID+C, BD+C low-emitting interiors
Collaborative for High Performance Schools EQ 7.1.1 adhesives & sealants
Criteria of MAS Certified Green® Program low-emitting material
TVOC Emissions at 14-days 0.5 mg/m3 or less

Bracketed
Products: TEC ® Liquidam™, Chapco ® Defender ™

Test Date
& Report No.: 10/02/2018
1801335

Certificate No.: MAS1801335 valid December 2018 to December 2019



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by **Materials Analytical Services, LLC** - ISO/IEC 17025
3rd Party Product Certification by **MAS Certified Green®** - ISO/IEC 17065
*outside of A2LA accreditation scope

