



MAS Certified Green® Certificate of Compliance Low-Emitting Materials

Awarded to:

**FELTOUCH YAPI TASATIM SAN. TİC.A.Ş OF
ISTANBUL, TURKEY** 09 B BLOCK NO. 7/15 ®

Category:
Cert. Scheme:

Construction Material – Wall Panel
VOC Emissions

Accredited
Standards &
Test Methods:

California Dept. of Public Health Standard Method v1.2 classroom & private office

*Conforms
With:

LEED v4.1 ID+C, BD+C
(CHPS) 2019 Core Criteria EQ C6.1.6
Criteria of MAS Certified Green® Program
TVOC Emissions at 14-days

low-emitting interiors
ceiling & wall systems
low-emitting material
0.5 mg/m³ or less

Bracketed
Products:

Wall Panel Plates: 6mm Plate, 7mm Plate, DecoSound, Flatline.

Test Date:

8/26/2019

Report No.:1901066

Certificate No.: MAS1901066

valid August 2019 to August 2020



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) – ISO/IEC 17025:2017

3rd Party Product Certification by [MAS Certified Green®](#) – ISO/IEC 17065:2012

*outside of A2LA accreditation scope

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>