

# Low-Emitting Materials

## Certificate of Compliance

Awarded to: **FABRI TRAK SYSTEMS, INC. OF MT. LAUREL, NJ**

111 WEST LAUREL PARK DRIVE, ZIP CODE: 08054

Category: Construction Materials - Wall & Ceiling Products  
Cert. Scheme: VOC Emissions

Accredited  
Compliance  
Designation:

California Dept. of Public Health Standard Method v1.2 classroom, private office

\*Conforms  
With:

LEED v4 ID+C, BD+C  
Collaborative for High Performance Schools EQ 7.1.6  
Criteria of MAS Certified Green® Program  
TVOC Emissions at 14-days

low-emitting materials  
ceiling & wall systems  
low-emitting materials  
less than 0.5 mg/m<sup>3</sup>

Bracketed  
Products:

GeoTRAK® PVC-Free Stretch Wall and Ceiling Track

Test Date  
& Report No.:

05/31/2018  
1800706

Certificate No.: MAS1800706-2

valid June 2018 to June 2019



Testing Cert. # 2925.01  
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025  
3<sup>rd</sup> Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065  
\*outside of A2LA accreditation scope

