



MAS Certified Green® Certificate of Compliance Low-Emitting Materials

Awarded to:

**H.B. FULLER CONSTRUCTION PRODUCTS, INC. OF
ST. PAUL, MN** 1200 WILLOW LAKE BLVD.; ZIP CODE: 55110

Category:
Cert. Scheme:

Construction Materials - Flooring Systems
VOC Emissions

Accredited
Standards &
Test Methods:

California Dept. of Public Health Standard Method v1.2 classroom & private office

*Conforms
With:

LEED v4.1 ID+C, BD+C
(CHPS) 2019 Core Criteria EQ C6.1.2
Criteria of MAS Certified Green® Program
TVOC Emissions at 14-days

low-emitting interiors
flooring systems
low-emitting material
0.5 mg/m³ or less

Bracketed
Products:

Underlayment: TEC™ Level Set® 200, TEC™ Level Set® 300, TEC™ Level Set® Deep Pour 3, TEC™ EZ Level®, TEC™ Contractor Grade Self-Leveling Underlayment, TEC™ Level Set® LW-60, CHAPCO® Standard SLU, CHAPCO® Premium SLU & TEC™ Skill Set® Ultimate Self-Leveling Underlayment, Level Set 500 HF, LS500.

Test Date:

8/29/2019

Report No.: 1901095R2

Certificate No.: MAS1901095-2R3

valid September 2019 to September 2020



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017
3rd Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012

*outside of A2LA accreditation scope

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>