



# MAS Certified Green® Certificate of Compliance Low-Emitting Materials

Awarded to:

**H.B. FULLER CONSTRUCTION PRODUCTS, INC. OF  
AURORA, IL** 1105 SOUTH FRONTENAC STREET; ZIP CODE: 60504

Category:  
Cert. Scheme:

Construction Materials - Adhesives, Sealants & Coatings  
VOC Emissions

Accredited  
Standards &  
Test Methods:

California Dept. of Public Health Standard Method v1.2 classroom & private office

\*Conforms  
With:

LEED v4.1 ID+C, BD+C (classroom & office setting)  
CHPS 2019 Core Criteria 3.0 EQ C6.1.5  
Criteria of MAS Certified Green® Program  
TVOC Emissions at 14-days

low-emitting materials  
paints & coatings  
low-emitting materials  
0.5 mg/m<sup>3</sup> or less

Bracketed  
Products:

Weather Barrier Coatings: 35-00\*\*, 45-00, 46-50, 46-51, CP-9, CP-10, CP-10-1,  
CP-10-2, CP-11, CP-11-1, CP-11-2.

\*\*Product tested as representative exemplar of product bracket listed above.

Test Date:

July 10, 2020

Report No.: 2000414R1

Certificate No.: MAS2000414R2-2

valid July 2020 to July 2021



Testing Cert. # 2925.01  
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017  
3<sup>rd</sup> Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012

\*outside of A2LA accreditation scope

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>