



Low-Emitting Materials

Certificate of Compliance

Awarded to: **H.B. FULLER CONSTRUCTION PRODUCTS, INC. OF ST. PAUL, MN** 1200 WILLOW LAKE BOULEVARD; ZIP CODE: 55110

Category: Construction Materials – Adhesives, Sealants & Coatings
Cert. Scheme: VOC Emissions

Accredited Compliance Designation: California Dept. of Public Health Standard Method v1.2 classroom & private office

*Conforms With: LEED v4 ID+C, BD+C
Collaborative for High Performance Schools EQ 7.1.1
Criteria of MAS Certified Green® Program
TVOC Emissions at 14-days
low-emitting interiors
adhesives & sealants
low-emitting material
0.5 mg/m³ or less

Bracketed Products: Adhesives: 85-60, CP-126, 97-15, 85-62, 85-65, CP-125

Test Date & Report No.: 06/17/2019
1900678

Certificate No.: MAS1900678-8 valid June 2019 to June 2020



Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) – ISO/IEC 17025
3rd Party Product Certification by [MAS Certified Green®](#) – ISO/IEC 17065
*outside of A2LA accreditation scope