



MAS Certified Green® Certificate of Compliance Low-Emitting Materials

Awarded to:

**H.B. FULLER CONSTRUCTION PRODUCTS, INC. OF
AURORA, IL** 1105 SOUTH FRONTENAC STREET; ZIP CODE: 60504

Category:
Cert. Scheme:

Construction Materials – Adhesives, Sealants & Coatings
VOC Emissions

Accredited
Standards &
Test Methods:

California Dept. of Public Health Standard Method v1.2 classroom & private office

*Conforms
With:

LEED v4.1 ID+C, BD+C (classroom & office setting)
CHPS 2019 Core Criteria 3.0 EQ C6.1.5
Criteria of MAS Certified Green® Program
TVOC Emissions at 14-days

low-emitting materials
paints & coatings
low-emitting materials
0.5 mg/m³ or less

Bracketed
Products:

IAQ Coatings: 40-11, 40-20, 40-20C, 40-25**, 40-25A, 40-30, 40-50.

**Product tested as representative exemplar of product bracket listed above.

Test Date:

July 10, 2020

Report No.: 2000414R1

Certificate No.: MAS2000414R2-6

valid July 2020 to July 2021



Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017
3rd Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012

*outside of A2LA accreditation scope

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>