



MAS Certified Green® Certificate of Compliance Low-Emitting Materials

Awarded to:

ARMACELL, LLC OF CHAPEL HILL, NC

55 VILCOM CENTER DRIVE #200; ZIP CODE: 27514

Category:

Construction Materials – Interior Adhesives, Glues, Sealants & Coatings

Cert. Scheme:

VOC Emissions

Accredited

Standards &

Test Methods:

California Dept. of Public Health Standard Method v1.2 classroom & private office

*Conforms

With:

LEED v4.1 ID+C, BD+C

(CHPS) 2019 Core Criteria 3.0 EQ C6.1.1

Criteria of MAS Certified Green® Program

TVOC Emissions at 14-days

low-emitting interiors

adhesives & sealants

low-emitting material

0.5 mg/m³ or less

Bracketed

Products:

520 BLV Adhesive

Test Date:

7/26/2019

Report No.: 1900964

Certificate No.: MAS1900964b-A

valid August 2019 to August 2020



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by **Materials Analytical Services, LLC** - ISO/IEC 17025:2017

3rd Party Product Certification by **MAS Certified Green®** - ISO/IEC 17065:2012

*outside of A2LA accreditation scope

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>