

## Low-Emitting Materials

## Certificate of Compliance

Awarded to:

## MON-ECO INDUSTRIES, INC OF EAST BRUNSWICK, NJ

5 JOANNA COURT, ZIP CODE: 08816

Category: Cert. Scheme: Construction Materials - Interior Adhesives, Glues, Sealants & Coatings

**VOC Emissions** 

Accredited

Compliance Designation:

California Dept. of Public Health Standard Method v1.2 classroom, private office

\*Conforms

LEED v4 ID+C, BD+C

With:

Collaborative for High Performance Schools EQ 7.1.1

Criteria of MAS Certified Green® Program

TVOC Emissions at 14-days

low-emitting interiors adhesives & sealants low-emitting material 0.5 mg/m<sup>3</sup> or less

Bracketed Products:

Duct Sealants: 44-39 Eco-Duct Seal, 44-50 Eco-Duct Seal, 44-52 Eco-Duct Seal, 44-52

Eco-Duct Seal Low VOC, 48-81 Eco-Duct Seal

Test Date 03/20/2019 & Report No.: 1900275

Certificate No.: MAS1900275-2

valid March 2019 to March 2020



Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by Materials Analytical Services, LLC - ISO/IEC 17025 3<sup>rd</sup> Party Product Certification by MAS Certified Green® - ISO/IEC 17065 \*outside of A2LA accreditation scope