



MAS Certified Green® Certificate of Compliance Low-Emitting Materials

YURTBAY SERAMIK OF ISTANBUL, TURKEY

OKLUBALI MAH. INONU-ESKİŞEHİR, TURKEY 26670

Awarded to:

Category: Construction Materials - Flooring
Cert. Scheme: VOC Emissions

Accredited
Standards &
Test Methods:

California Dept. of Public Health Standard Method v1.2 classroom & private office

*Conforms
With:

LEED v4.1 ID+C, BD+C
(CHPS) 2019 Core Criteria 3.0 EQ C6.1.2
Criteria of MAS Certified Green® Program
TVOC Emissions at 14-days

low-emitting interiors
flooring systems
low-emitting material
0.5 mg/m³ or less

Bracketed
Products:

Yurtbay Seramik Porcelain Tile

Test Date:

9/26/2019

Report No.: 1901179

Certificate No.: MAS1901179c

Valid: September 2019 to September 2020



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017
3rd Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012

*outside of A2LA accreditation scope

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>