



MAS Certified Green® Certificate of Compliance Low-Emitting Materials

Awarded to:

**RIKETT AMERICA HOLDING, INC. OF CITY OF
INDUSTRY, CA** 17870 CASTLETON ST., SUITE 665; ZIP CODE: 91748

Category:
Cert. Scheme:

Construction Material - Flooring
VOC Emissions

Accredited
Standards &
Test Methods:

California Dept. of Public Health Standard Method v1.2 classroom & private office

*Conforms
With:

LEED v4.1 ID+C, BD+C
(CHPS) 2019 Core Criteria 3.0 EQ C6.1.2
Criteria of MAS Certified Green® Program
TVOC Emissions at 14-days

low-emitting interiors
flooring systems
low-emitting material
0.5 mg/m³ or less

Bracketed
Products:

RESO Luxury Vinyl Tile: RESO LVT, RESO LVT Click, Rigid Core LVT and
Dry Back LVT (Includes 2.0mm, 2.5mm, 3.0mm, 4.0mm, and 5.0mm thicknesses)

Test Date:

12/18/2019

Report No.: 1901476

Certificate No.: MAS1901476a

valid January 2020 to January 2021



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017
3rd Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012
*outside of A2LA accreditation scope

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>