



MAS Certified Green® Certificate of Compliance Low-Emitting Materials

Awarded to:

DURO DYNE CORPORATION OF BAY SHORE, NY

81 SPENCE STREET, ZIP CODE: 11706

Category:
Cert. Scheme:

Construction Materials - Interior Adhesives, Glues, Sealants & Coatings
VOC Emissions

Accredited
Standards &
Test Methods:

California Dept. of Public Health Standard Method v1.2 classroom, private office

*Conforms
With:

LEED v4.1 ID+C, BD+C
(CHPS) 2019 Core Criteria 3.0 EQ 6.1.1
Criteria of MAS Certified Green® Program
TVOC Emissions at 14-days

low-emitting interiors
adhesives & sealants
low-emitting material
0.5 mg/m³ or less

Bracketed
Products:

RPG Low VOC Adhesive

Test Date:

7/26/2019

Report No.: 1900964

Certificate No.: MAS1900964B-DD1

valid August 2019 to August 2020



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025:2017

3rd Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065:2012

*outside of A2LA accreditation scope

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>