



Low-Emitting Materials

Certificate of Compliance

Awarded to:

LV WOOD OF NEW YORK, NY

24 WEST 20TH STREET, ZIP CODE: 10011

Category:

Construction Materials – Flooring

Cert. Scheme:

VOC Emissions

Accredited

Compliance

Designation:

California Dept. of Public Health Standard Method v1.2 classroom & private office

*Conforms

With:

LEED v4 ID+C, BD+C

Collaborative for High Performance Schools EQ 7.1.2

Criteria of MAS Certified Green® Program

TVOC Emissions at 14-days

low-emitting interiors

flooring systems

low-emitting material

0.5 mg/m³ or less

Bracketed

Products:

Wood Flooring

Test Date

& Report No.:

04/19/2019

1900505

Certificate No.:

MAS1900505

valid April 2019 to April 2020



Testing Cert. # 2925.01

Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025

3rd Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065

*outside of A2LA accreditation scope