



Low-Emitting Materials

MAS Certified Green® Certificate of Compliance

Awarded to:

HERCULES INDUSTRIES, INC. OF DENVER, CO

1310 W. EVANS AVENUE; ZIP CODE: 80223

Category:

Construction Materials - Interior Adhesives, Glues, Sealants & Coatings

Cert. Scheme:

VOC Emissions

Accredited

Compliance

Designation:

California Dept. of Public Health Standard Method v1.2 classroom & private office

*Conforms

With

LEED v4 ID+C, BD+C

Collaborative for High Performance Schools EQ 7.1.1

Criteria of MAS Certified Green® Program

TVOC Emissions at 14-days

low-emitting interiors

adhesives & sealants

low-emitting material

0.5 mg/m³ or less

Bracketed

Products:

Duct Sealants:

MTS100, MTS200, MTS300, MTS300W, MTS400, MTS500

Test Date

2/22/2019

& Report No.:

1900129

Certificate No.:

MAS1900129

valid March 2019 to March 2020



Testing Cert. # 2925.01

Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by [Materials Analytical Services, LLC](#) - ISO/IEC 17025

3rd Party Product Certification by [MAS Certified Green®](#) - ISO/IEC 17065

*outside of A2LA accreditation scope